

# LOGGING NEAR POWERLINES EMERGENCY CONTACT FORM

**Emergency number in event of electrical contact: 911**

Circuit Number (s): _____ Structure : _____ to Structure _____ Voltage: _____ General Limits of Approach - Minimum Distance: _____ Distribution Under build / Adjacent Circuit: _____	<b>General Limits of Approach</b>  <table border="1"> <thead> <tr> <th rowspan="2">Voltage Phase to Phase</th> <th colspan="2">Minimum Distance</th> </tr> <tr> <th>Metres</th> <th>Feet</th> </tr> </thead> <tbody> <tr> <td>Over 750 V to 75 kV</td> <td>3</td> <td>10</td> </tr> <tr> <td>Over 75 kV to 250 kV</td> <td>4.5</td> <td>15</td> </tr> <tr> <td>Over 250 kV to 550 kV</td> <td>6</td> <td>20</td> </tr> </tbody> </table>	Voltage Phase to Phase	Minimum Distance		Metres	Feet	Over 750 V to 75 kV	3	10	Over 75 kV to 250 kV	4.5	15	Over 250 kV to 550 kV	6	20
Voltage Phase to Phase	Minimum Distance														
	Metres	Feet													
Over 750 V to 75 kV	3	10													
Over 75 kV to 250 kV	4.5	15													
Over 250 kV to 550 kV	6	20													

BC Hydro – Local Contact Information			
Title:	Name:	Office:	Mobile:

Logging Operator Name : _____ Logging Supervisor: _____ Emergency Contact Number : _____ Office Contact Number : _____ Owner / Licensee Contact : _____	Land Owner / Forest Licensee: _____ BC Forest Safe Certification No: _____ Cutting Permit / Block No: _____ Location/ Road : _____ Proposed Logging Dates: _____
---	--

## Site Conditions & Stand Description

Trees or parts of trees are within General limits of approach ( LOA):

Trees or parts of trees may fall within LOA or may fall and damage electrical structures or guywires

**Note: Only a Certified Utility Arborist or Qualified Electrical Worker who is authorized by the owner of the power system to do such work can fall, remove, top or prune trees/vegetation that is within the minimum distance for General Limits of approach (LOA) . Trees that are not within limits of approach but may fall within minimum limits of approach or hit electrical equipment must be felled in a manner approved by WorksafeBC.**

An inspection has been completed to identify any hazardous areas, including situations where any part of a tree to be pruned or felled is within the applicable minimum distance from an energized conductor as specified in (General Limits of Approach, Table 19-1A) or may fall within that distance.

Logging Contractor - Representative	Date:
-------------------------------------	-------

BC Hydro - Electrical Utility - Representative	Date:
--	-------

**All contacts, incidents, close calls damage involving electrical infrastructure must be immediately reported to a BC Hydro Representative**